



Stair Nosing Australia

Slip Check to AS 4586:2013 700 (SMN515) Series Stair Nosing Insert

NATA Accreditation Number 17139

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Accredited for compliance with ISO/IEC 17025

NATA is a signatory to the APLAC mutual recognition arrangement for the mutual recognition of the equivalence of testing, calibration and inspection reports

tair Nosi

tai

Safe Environments Pty Ltd Unit 4, 40 Bessemer Street, Blacktown NSW 2148 Australia

T (+61) (2) 9621 3706 F (+61) (2) 9621 8891

ABN 80 118 534 7688 www.SafeEnvironments.com.au info@safeenvironments.com.au

A division of Safe Environments Pty Ltd www.SafeEnvironments.com.au

4/40 Bessemer Street Blacktown NSW 2148 Phone 02 9621 3706 ABN 80 118 534 768

16 March 2018

Test Report No. R9631

Slip Resistance Classification of New Pedestrian Surface Materials

AS 4586:2013 Appendix A (Wet Pendulum Test)

The slip resistance Classification has been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface.

Requested by: Walmay Architectural Products -

Client Address: PO Box 144

Kellyville NSW 2155

Product Manufacturer: Manufacturerd by Walmay Architectural Products-

Product Description: Distributed by Stair Nosing Australia

700 (SMN515) Series Stair Nosing Insert

Test conducted according to:

Location: AS 4586:2013 Appendix A

Conducted by: Slip Check Pty Ltd Test Facilities, Blacktown NSW 2148

Stuart Lumsden

Date: 16 October 2019 Temperature: 27°C Sample: Unfixed Cleaning: None

Rubber slider used: Slider 96 Conditioned: Grade P 400 paper dry followed

Slope of specimen: Tested on a flat level surface

Direction of Test: Direction of travel, perpendicular to nosings

	Specimen 1	Specimen 2	Specimen 3	Specimen 4	Specimen 5
Mean BPN of last 3 swings:	44	45	46	45	45

Reported SRV of Sample:	45	
Class:	P4	

Aluminum Ripple Trim Inserts

by wet lapping film



Ryan Voorderhake **Materials Manager**

Safe Environments Pty Ltd R7701.1 - Slip Check, 700 Series 16 October 2019

