

## **Slip Check to AS 4586:2013**

### **400 Series Inserts**

**This report replaces report R7701**

NATA Accreditation Number 17139

The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards

Accredited for compliance with ISO/IEC 17025

NATA is a signatory to the APLAC mutual recognition arrangement for the mutual recognition of the equivalence of testing, calibration and inspection reports

16 March 2018

## Test Report No. R7701.1

This report replaces report R7701

### Slip Resistance Classification of New Pedestrian Surface Materials

AS 4586:2013 Appendix A (Wet Pendulum Test)

The slip resistance Classification has been determined for unused surfaces using specific conditions. Factors such as usage, cleaning systems, applied coatings and patterns of wear may affect the characteristics of the surface.

Requested by: Stair Nosing Australia-  
Client Address: PO Box 144  
Kellyville NSW 2155  
Product Manufacturer: 400 Series - Distributed by Stair Nosing Australia  
Product Description:  
Test conducted according to: AS 4586:2013 Appendix A  
Location: Slip Check Pty Ltd Test Facilities, Blacktown NSW 2148  
Conducted by: Stuart Lumsden

Date: 16 March 2018  
Sample: Unfixed  
Rubber slider used: Slider 96  
Slope of specimen: Tested on a flat level surface  
Direction of Test: Direction of travel, perpendicular to nosings  
Temperature: 27°C  
Cleaning: None  
Conditioned: Grade P 400 paper dry followed by wet lapping film

	Specimen 1	Specimen 2	Specimen 3	Specimen 4	Specimen 5
Mean BPN of last 3 swings:	74	73	74	74	72

<b>Reported SRV of Sample:</b>	<b>73</b>
<b>Class:</b>	<b>P5</b>



  
Ryan Voorderhake  
Materials Manager

